



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

November 21, 2019
Subject: Large Culvert Replacement
State WIN: 022849.00
Location: **Danforth**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Will the Department allow the temporary aerial utility relocation and reset be conducted outside the 45-calendar day completion period?

Response: Yes, the Department will allow for extended utility relocation beyond the 45-day work window. Coordination of utilities will be the responsibility of the awarded Contractor. Additionally, please refer to Utility specification 104 for other related accommodations and needs for the utility move.

Question: Will the Department allow the use of a solar portable traffic signal system? Example: Horizon SQ3TS

Response: The use of solar portable traffic signals would be allowed granted that they meet the specification requirements in the 643 Special Provision Page 98, paid for under Item # 643.72 Temporary Traffic Signals LS. Please verify with the manufacturer of the Horizon SQ3TS that it meets specifications noted in the Special Provision.

Consider these changes and information prior to submitting your bid on **November 27, 2019**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer